

ADDENDUM NO. 1

Town of North Attleboro, MA

**Replacement of Bridge N-16-14,
Chestnut Street Bridge over Ten Mile River,
Contract No. 20-422-070**

The following changes and additional information are hereby made part of the Contract Documents. Bidders are advised that this Addendum must be acknowledged in the appropriate space provided on the Bid Form.

Upon receipt of this addendum, each bidder must sign the Verification of Receipt Form in Attachment 1 of this Addendum No. 1 and send that page to BETA Group, Attention Christopher Jones, by email at cjones@beta-inc.com or by fax at 781-255-1974.

QUESTIONS AND ANSWERS

- Q1. Is there a flow rate available for the sewer main to be bypassed?
- A1. The typical sewer flow rate is not known and is anticipated to fluctuate based on infiltration and inflow from rain events and groundwater elevation changes. The maximum capacity of the gravity sewer main is 1,200 gpm.

END OF ADDENDUM NO. 1

ADDENDUM NO. 1 VERIFICATION OF RECEIPT

Town of North Attleboro, MA

**Replacement of Bridge N-16-14,
Chestnut Street Bridge over Ten Mile River,
Contract No. 20-422-070**

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 1 BY SIGNING BELOW AND RETURNING THIS SHEET ONLY TO BETA GROUP, ATTENTION CHRISTOPHER JONES, BY EMAIL AT CJONES@BETA-INC.COM OR BY FAX AT 781-255-1974.

Receipt of Addendum No. 1 is hereby acknowledged:

Signature: _____

Name: _____
(Please Print)

Title: _____

Company: _____

Date: _____