



Charles D. Baker, Governor  
Karyn E. Polito, Lieutenant Governor  
Jamey Tesler, Secretary & CEO  
Jonathan L. Gulliver, Highway Administrator



October 7, 2021

608603-116295

ADDENDUM NO. 1

To Prospective Bidders and Others on:

**DUNSTABLE**  
**FAP#S CMQ-0033(022)X, STP-0033(022)X & TAP-0033(022)X**  
**Roadway Reconstruction and Related Work on a Section of Main Street (Route 113)**

BIDS TO BE

OPENED AND READ:

TUESDAY, DECEMBER 21, 2021 at 2:00 P.M.

Transmitting revisions to the Contract Documents as follows:

RESPONSE TO

CONTRACTOR'S QUESTION:

1 Page

Please take note of the above and acknowledge Addendum No. 1 in your Expedite Proposal file before submitting your bid.

Very truly yours,

Eric M. Cardone, P.E.  
Construction Contracts Engineer

EMC/jmr

c: William F Brown, Project Manager

**THIS PAGE INTENTIONALLY LEFT BLANK**

**DUNSTABLE**  
**FAP#S CMQ-0033(022)X, STP-0033(022)X & TAP-0033(022)X**  
**Roadway Reconstruction and Related Work on a Section of Main Street (Route 113)**  
(608603-116295)

RESPONSE TO CONTRACTOR'S QUESTION

ADDENDUM NO. 1, OCTOBER 7, 2021

---

**Advanced Drainage Systems, Inc. email dated October 5, 2021:**

**Question #1:** The Project is currently specified with 12- and 18-inch Reinforced Concrete Pipe. Item Numbers and quantities are as follow:

241.12 = 12-Inch Reinforced Concrete Pipe (1,155 LF)

241.18 = 18-Inch Reinforced Concrete Pipe (125 LF)

We would like to respectfully request that corrugated plastic pipe (both polyethylene and polypropylene; per AASHTO M294 and AASHTO M330) be allowed under the pipe option for the above referenced item. Both pipe materials are included within the Commonwealth of Massachusetts Department of Transportation Standard Specifications for Highways and Bridges (2021 Edition) Division III-Materials Specifications, Section M5.03.10 Corrugated Plastic Pipe. If allowed, the installation of corrugated plastic pipe would follow MassDOT Installation Guidelines.

**Response #1:** Reinforced concrete pipe shall be used for this project according with contract documents.