

TOWN OF MADISON, CONNECTICUT
CONTRACT DOCUMENTS
FOR
REPLACEMENT OF BRIDGE NO. 04852 AND NO. 075002
COUNTY ROAD OVER THE HAMMONASSET RIVER
MADISON, CT

ADDENDUM NO. 2
October 28, 2021

All BIDDERS are hereby notified and warned of the following addition to the CONTRACT DOCUMENTS:

1. Received and answered the following question:
 - Q1. "Please refer to plan sheet 34 of 50. Note 2 Section E and F refer to pay items that are not included in the Bid Form. Please provide."
 - A1. Delete notes 2.E and 2.F.
 - Q2. "Please refer to Plan sheet 36 of 50. Note 4 States no dead load or live loads shall be permitted until all the transverse ties have been fully tensioned, however, shear key longitudinal grouting is required prior to full tension. Please advise."
 - A2. On sheet 36 of 50, under "Transverse Strand Post-Tensioning Procedure", note 4 – before the word "shall", insert the following words ", in excess of those needed to accomplish the work in notes 1 through 3 immediately above,".

END OF ADDENDUM NO. 2