



**Town of Wendell – REBID Farley Rd. Bridge #E-10-006=W-15-005
IFB 2025-2163**

ADDENDUM 1 – July 23, 2025

Please note the following submitted questions:

- 1. I have reviewed the Proposed Deck To Stringer Connection Detail on Sheet 2 of the Farley Road Bridge plans. Is there a fastening schedule, method or detail for connecting the 4"x 6" timber planks to one another?*

RESPONSE 1: There is no connection between boards other than timber wearing surface providing a connection. Each board is directly connected to the steel stringer with steel Z-clips.

- 2. Is connecting the 4"x 6" timbers to one another required at all?*

RESPONSE 2: No

The MassDOT Prequalification Amount and Class of Work have been established:

Prequalification Amount:	\$403,200.00
Class of Work:	Bridge Construction

Sealed bids are due on AUGUST 13, 2025 at 2PM.

Please acknowledge ADDENDUM 1 on the bid signature page.

All other provisions of the Invitation for Bids remain unchanged.

Ellen Batchelder
Franklin Regional Council of Governments
Assistant Procurement Officer
July 23, 2025