



Maura Healey, Governor
Kimberley Driscoll, Lieutenant Governor
Monica Tibbitts-Nutt, Secretary & CEO
Jonathan L. Gulliver, Highway Administrator



August 5, 2025

608491-131468

ADDENDUM NO. 2

To Prospective Bidders and Others on:

MENDON

**Federal Aid Project No. NHP(NHS)-003S(866)X
Resurfacing and Related Work on Route 16**

THIS PROPOSAL TO BE OPENED AND READ: TUESDAY, AUGUST 19, 2025, AT 2:00 P.M.

Transmitting changes to the Contract Documents as follows:

QUESTION AND RESPONSE: 1 page.

DOCUMENT 00104: Revised page 1.

Please take note of the above, substitute the revised page for the original, and acknowledge Addendum No. 2 in your Expedite Proposal file before submitting your bid.

Very truly yours,

Eric M. Cardone, P.E.
Construction Contracts Engineer

JPB
cc: Kimberly Sloan, Project Manager

THIS PAGE INTENTIONALLY LEFT BLANK

MENDON
Federal Aid Project No. NHP(NHS)-003S(866)X
Resurfacing and Related Work on Route 16
(608491-131468)

Question and Response

Addendum No. 2, August 5, 2025

Advanced Drainage Systems. e-mail dated August 1, 2025.

Question 1.) I am writing in regard to the Resurfacing and Related Work on Route 16 Project in Mendon, MA. Specifically, this Project is MassDOT Project Number 608491 and Bid Number BD-25-1030-0H100-0H002-119046; it is also Federal Aid Project No. NHP(NHS)-003S(866)X. The Project is currently specified with 12-, 15-, 18- & 30-inch Reinforced Concrete Pipe (RCP) Class III, 12-, 15- & 18-inch RCP Class IV, and 12-, 15- & 18-inch RCP Class V. Item Number and quantities are as follows:

241.12 = 12-Inch Reinforced Concrete Pipe Class III (4,135 LF)
241.15 = 15-Inch Reinforced Concrete Pipe Class III (2,740 LF)
241.18 = 18-Inch Reinforced Concrete Pipe Class III (705 LF)
241.30 = 30-Inch Reinforced Concrete Pipe Class III (15 LF)
243.12 = 12-Inch Reinforced Concrete Pipe Class IV (1,600 LF)
243.15 = 15-Inch Reinforced Concrete Pipe Class IV (245 LF)
243.18 = 18-Inch Reinforced Concrete Pipe Class IV (130 LF)
244.12 = 12-Inch Reinforced Concrete Pipe Class V (240 LF)
244.15 = 15-Inch Reinforced Concrete Pipe Class III (245 LF)
244.18 = 18-Inch Reinforced Concrete Pipe Class III (85 LF)

We would like to respectfully request that corrugated plastic pipe (both polyethylene and polypropylene; per AASHTO M294 and AASHTO M330) be allowed under the pipe option for the above referenced items. Both pipe materials are included within the Commonwealth of Massachusetts Department of Transportation Standard Specifications for Highways and Bridges (2025 Edition) Division III-Materials Specifications, Section M5.03.10 Corrugated Plastic Pipe. If allowed, the installation of corrugated plastic pipe would follow MassDOT Installation Guidelines. If additional information shall be required, please contact me at your earliest convenience regarding this request for a storm drainage pipe alternative. Thank you for your time and consideration.

Response 1.) The designer has specified RCP for this project as such the corrugated plastic pipe will not be allowed under a pipe option.

② Addendum No. 2, August 5, 2025

DOCUMENT 00104

**NOTICE TO CONTRACTORS**

Electronic proposals for the following project will be received through the internet using www.bidx.com until the date and time stated below and will be posted on www.bidx.com forthwith after the bid submission deadline. No paper copies of bids will be accepted. All Bidders must have a valid vendor code issued by MassDOT in order to bid on projects. Bidders need to apply for a Digital ID at least 14 days prior to a scheduled bid opening date with www.bidx.com.

TUESDAY, AUGUST 19, 2025 at 2:00 P.M. ****MENDON****Federal Aid Project No. NHP(NHS)-003S(866)X
Resurfacing and Related Work on Route 16******Date Subject to Change**② PROJECT VALUE = \$17,857,000.00

Bidders must be pre-qualified by the Department in the HIGHWAY - CONSTRUCTION category to bid on the above project. An award will not be made to a Contractor who is not pre-qualified by the Department prior to the opening of Proposals.

All prospective Bidders who intend to bid on this project must obtain "Request Proposal Form (R109)". The blank "Request Proposal Form (R109)" can be obtained at:
<https://www.mass.gov/prequalification-of-horizontal-construction-firms>.

All prospective Bidders must complete and e-mail an electronic copy of "Request Proposal Form (R109)" to the MassDOT Director of Prequalification for approval:
prequal.r109@dot.state.ma.us.

Proposal documents for official bidders are posted on www.bidx.com. Other interested parties may receive informational Contract Documents containing the Plans and Special Provisions, free of charge.

Bids will be considered, and the contract awarded in accordance with statutes governing such contracts in accordance with Massachusetts General Laws Chapter 30 § 39M.

The Project Bids File Attachments folder for proposals at www.bidx.com shall be used for submitting at the time of bid required information such as the Bid Bond required document, and other documents that may be requested in the proposal.