



Franklin Regional
Council of Governments

Town of Charlemont – Legate Hill Rd Bridge #C-05-054
IFB 2025-2177

ADDENDUM 2– November 24, 2025

Please note the following submitted questions:

1. *Plans sheet 1 of 9 calls out anchor bolts and nuts to be grade 36, page 22 of 115 of specs says grade 105. Please clarify.*

RESPONSE 1: All anchor bolts shall be Grade 36.

2. *Are Glued Laminated Timber Bridge fasteners to be galvanized and same grade as the anchor bolts?*

RESPONSE 2: Yes, all bolts shall be galvanized and Grade 36.

3. *What is a suitable epoxy resin to fill the holes in tops of the Timber deck beams at the anchor bolt locations?*

RESPONSE 3: Any epoxy shown on MassDOT's QCML list shall be acceptable.

The MassDOT Prequalification Amount and Class of Work have been established:

Prequalification Amount: \$412,093.00

Class of Work: Bridge - Construction

Sealed bids are due on DECEMBER 16, 2025 at 2PM.

Please acknowledge ADDENDUM 2 on the bid signature page.

All other provisions of the Invitation for Bids remain unchanged.

Ellen Batchelder
Franklin Regional Council of Governments
Assistant Procurement Officer
November 24, 2025