

**ADDENDUM NO. 3
TO
BIDDING AND CONTRACT REQUIREMENTS AND SPECIFICATIONS
FOR
HOP BROOK CULVERT REPLACEMENT
WARREN WRIGHT ROAD
BELCHERTOWN, MA
June 3, 2026**

As a point of clarification, it should be understood that the Contract Documents govern all aspects of the project. Discussions held during the Pre-Bid Conference or over phone or email are informal and informational only. All official changes to the Contract Documents are made only by addenda.

The following additional information is hereby made a part of the Contract Documents.

GENERAL:

1. This addendum clarifies the response to Question #2 on Addendum No. 2.

ATTACHMENTS:

1. Question and answer document.

Please note that the bid opening will still take place at 3 PM on June 4, 2026 as no changes were made to the Contract Documents.

END OF ADDENDUM NO.3

Questions and Answers
Hop Brook Culvert Replacement
Warren Wright Road
Belchertown, MA

Questions received over email with responses are provided below.

Q: Addendum 2 answer to question 2 references the bridge approach slab shelf. Please confirm there are no approach slabs on this project. An approach seat is noted on sheet 10 but there are no dimensions or details provided for an approach slab. Please advise.

A: Neither approach slabs nor approach slab shelves are required for either structure for this project per the plans. The addition of an approach slab shelf and approach slabs as part of the Fabricator's/Contractor's delegated design is allowed provided the delegated design process is followed per the Contract Documents.