



Addendum No. 1, IFB No. 27-13

Springfield Reservoir Culvert Replacement Project

Date of Addendum: October 8, 2026

Bid Opening Date: 2:00 P.M. October 22, 2026

To Whom It May Concern:

This is an addendum to the above IFB. Special attention should be given to this addendum to preserve the validity of any bids submitted in response to this request. All Addenda must be acknowledged by indicating receipt on page 2 of Section 00300, Forms for General Bid. Failure to acknowledge this Addendum may subject the Bidder to disqualification.

1. PRE-BID MEETING:

- a. The Commission held a non-mandatory the Pre-Bid Meeting, as scheduled, on October 6, 2026. A copy of the attendance record from the meeting is included with this addendum as **Attachment 1**. A copy of the agenda that was distributed at the meeting is provided as **Attachment 2**.

Sincerely,

A handwritten signature in black ink, appearing to read "E. J. Sweeney", is written over the printed name.

Edward J. Sweeney, Chief Procurement Officer
Springfield Water and Sewer Commission

END OF ADDENDUM NO. 1 (not including attachments)

ATTACHMENT #1



Springfield Water and Sewer Commission Pre Bid Meeting Record of Attendance

IFB No: 27-13 Springfield Reservoir Culvert Replacement

Date: October 6, 2026

NAME	COMPANY NAME	PHONE	EMAIL
Jay Gagliarducci	Gagliarducci	413-543-6978	INFO@Gagliarducci.com
Zach Colburn	NHD	802-591-1132	Zcolburn@NeilHDaniels.com
Andrew Gordon	Tiand Bond	603-283-8444	AGORDON@TIANDBOND.com
David Fernandes	C.A Construction	413-331-5317	david@Canda-Construction.com
Brian Koshinsky	CD Davenport	413-774-2080	Brian@Cddavenport.com
SEBASTIAN LABONTE	J.L. RAYMAAKERS & SONS	(413) 562-0601	SEBASTIAN@RAYMAAKERS.COM
Tucker Collins	Collins & Sons Excavating	413-231-7543	collinsandsonsexcavating@yahoo.com
Colin Powers	Tighe + Bond	413-250-5278	cdpowers@tighebond.com
Ted Sweeng	SWSC	413 452 1300 x164	edward.sweeng@waterandsewer.com
Matt Baker	J.S. Rae	413-834-3190	mbaker@jsrae.com
Sam Duda	B.R. Bak Enterprises	413-537-6706	sduda@brbak.com
Taylor Hanks	SomCo Eco	978-235-6622	Tehanks@somcoeco.com

ATTACHMENT #2

Springfield Reservoir Culvert Replacement Springfield Water and Sewer Commission

LOCATION: Springfield Reservoir, 1149 Center Street, Ludlow, MA

DATE: October 6, 2026

START TIME: 10:00 a.m.

1. Introductions

- a. Owner & Engineer Introductions
- b. Sign-in Sheet

2. Procurement Requirements

- a. **Bid Opening – October 22, 2026 at 2:00 p.m.** Springfield Water and Sewer Commission, John J. Lyons Administration Building, Attn: Edward J. Sweeney, Chief Procurement Officer, 250 M Street Extension, Agawam, MA 01101.

b. Preparation of Bid

- i. Refer to Section 00100, Information to Bidders.
- ii. Submit 1 copy of complete Bid package (Section 00300 & other forms Section 00200). Include all form dividers, bind with a binder clip, and print documents single sided to aid with scanning and review of the Bid package.
- iii. Written questions must be received by October 13, 2026 at 4:30 p.m. or the questions may not be answered. Questions shall be addressed to Edward J. Sweeney, Chief Procurement Officer (Edward.sweeney@waterandsewer.org)
- iv. Addenda will be issued at least 3 business days prior to Bid opening.

c. Bidder Qualifications

- i. Completed three projects in the last five years which included coordination and work of a comparable scope and complexity as this Project, including but not limited to: culvert replacement, storm drain pipe installation, retaining walls, stream restoration work.

3. Project Description

- a. Furnishing and installation of approximately 26 linear feet of 72" x 60" precast concrete culvert (Culvert 1) across West Side Drive with 24" stone lined bottom and new headwalls to replace an existing stone culvert at the same location, and Furnishing and installation of approximately 26 linear feet of 36" x 24" precast concrete culvert (Culvert 2) across West Side Drive without stone lined bottom and new headwalls to replace an existing 24" corrugated metal culvert at the same location
- b. Demolition and removal of the existing culvert and headwalls
- c. Clearing and grubbing
- d. Temporary stream flow diversion system for stream crossings including coffer dam
- e. Furnishing and installation of wood guardrail at both culvert locations

- f. Repaving West Side Drive at both culvert locations
- g. Site restoration

4. Project Coordination/Work Constraints

- a. All components of the existing facility must remain in operation throughout construction of the new facility unless otherwise specified herein or in Section 01310.
- b. At no time will the Contractor obstruct any day-to-day activities of the Owner's operations or the Owner's staff.
- c. Obtain permits and approvals for use of any land and access thereto that is deemed necessary for the Work, where such land is not available for use by the Owner, including land for temporary construction facilities, access and egress, or for storage of materials. Confine apparatus and storage to such additional areas.
- d. Obtain permits and written approvals from appropriate jurisdictional agencies for the use of premises not available for use by the Owner, including all offsite staging areas, borrow pits and waste areas. Submit copies of all permits and approvals to the Owner prior to using areas.
- e. Provide for the disposal of waste materials off-site in accordance with all applicable laws.
- f. Install stream flow diversion prior to any demolition in accordance with Section 01580.
- g. Contractor shall assume full responsibility for security of all his and his subcontractors' materials and equipment stored on the site.
- h. If directed by the Owner, Contractor shall move any stored items which interfere with operations of the Owner.
- i. Vehicle Access
 - i. The existing road must be maintained for Owner access. Coordinate with Owner as needed regarding possible road closures. Road may not be closed without prior approval.

5. Contract Times (Section 00500, Agreement)

- a. Substantial Completion - 180 days after Notice to Proceed
- b. Final Payment - 210 days after Notice to Proceed
- c. Liquidated Damages - \$1,500 per day

6. Hazardous Materials/Asbestos Abatement

- a. N/A.

7. Permits

- a. Owner-Provided Permits
 - i. MassDEP 401 Water Quality Certification permit. A copy of the permit is included in Section 00800.
 - ii. Negative Determination of Applicability.
- b. Contractor-Attained Permits
 - i. Permits and licenses of a temporary nature necessary to perform the Work.
 - ii. Permits for disposal of construction waste, hazardous materials, and asbestos abatement.
 - iii. Other permits or licenses required for the Contractor's operations.
 - iv. Required elsewhere in the Contract Documents and not included herein.

8. Working Hours (Section 01140, Work Restrictions)

- a. Conduct work during weekdays, between the hours of 7:00 a.m. and 3:30 p.m. No equipment or machinery may be started at the site before 7:00 a.m. and all equipment must be shut off by 3:30 p.m.
- b. No work on Sundays, or on official Owner holidays.
- c. Extended hours and work on Saturdays requires SWSC approval in writing.
- d. Cold weather work during winter months is permissible provided work complies with all specification requirements.

9. Progress Payments (Section 00500 Agreement)

- e. Monthly payments – 5% retainage withheld
- f. Substantial Completion – Retainage based on estimated fair value of claims against the Contractor for completing incomplete or unsatisfactory work, work, and work done by subcontractors.

10. Final Payment (Article 14.07, Section 00700)

- a. Contractor submits final Application for Payment, including
 - Documentation required by Contract Documents, including evidence of insurance
 - Consent of surety to final payment
 - List of unsettled claims against Owner & Contractor
 - Release of liens
- b. Waiver of Claims

11. Correction Period (Article 13.07, Section 00700)

- a. 1-year after Substantial Completion